

June 5, 2018

For Immediate Release

Infrastructure Fund Issuer

Takara Leben Infrastructure Fund, Inc.

Representative: Masahide Kikuchi, Executive Director

Security Code: 9281

Management Company

Takara Asset Management Co., Ltd.

Representative: Mamoru Takahashi, President & CEO

Contact: Masahide Kikuchi, Vice President & Director of Investment Management Department, Infrastructure Fund Division

TEL: +81-3-6262-6402

Notice of Monthly Electricity Generation of Solar Power Generation Facilities for May 2018

Takara Leben Infrastructure Fund, Inc. hereby announces the monthly power generation of the solar power generation facilities under its ownership as of the end of May 2018 as follows.

【Monthly Electricity Generation】

Fiscal Period Ended May 2018					
	Number of Solar Power Site	Panel Output (kW)	Forecast Power Generation (kWh) (A) (Note)	Actual Power Generation (kWh) (B)	Difference (kWh) (B)-(A)
December	20	54,736.24	3,908,401	4,254,606	+346,205
January	20	54,736.24	4,409,256	4,290,670	-118,586
February	21	55,834.48	5,073,450	4,927,380	-146,070
March	21	55,834.48	6,275,801	6,575,020	+299,219
April	21	55,834.48	6,499,191	6,721,378	+222,187
May	21	55,834.48	6,698,915	7,137,387	+438,472
Total	21	55,834.48	32,865,014	33,906,441	+1,041,427

While May power generation in several areas in Kanto, Tohoku and Kyusyu region are slightly below the expected power generation, however, increased monthly sunshine duration throughout the nation resulted in electricity generation to reach 7,137,387kWh, which is 7% higher than the estimated electricity generation on the basis of the expected amounts of electricity generation in the 50th percentiles of probability of exceedance.

(Note) The estimated electricity generation is the total of the expected amounts of electricity generation in the 50th percentile of probability of exceedance calculated by a third party on the basis of the database for hourly solar radiation for a year and others

【Monthly Electricity Generation by Power Plant】

May 2018					
No.	Solar Power Site	Panel Output (kW)	Forecast Power Generation (kWh) (A) (note)	Actual Power Generation (kWh) (B)	Difference (kWh) (B)-(A)
S-01	LS Shioya	2,987.25	336,048	362,346	+26,298
S-02	LS Chikusei	1,205.67	130,533	147,154	+16,621
S-03	LS Chiba Wakabaku	705.10	79,173	82,836	+3,663
S-04	LS Miho	1,373.70	145,722	171,705	+25,983
S-05	LS Kirishima Kokubu	2,009.28	220,002	211,761	-8,241
S-06	LS Sosa	1,796.08	213,424	226,218	+12,794
S-07	LS Miyagi Osato	2,040.00	242,611	247,396	+4,785
S-08	LS Mito Takada	2,128.00	259,269	282,450	+23,181
S-09	LS Aomori Hiranai	1,820.00	243,313	234,946	-8,367
S-10	LS Tone Fukawa	2,467.08	298,208	313,986	+15,778
S-11	LS Kamisu Hasaki	1,200.00	161,768	159,995	-1,773
S-12	LS Tsukuba Bouchi	2,469.60	286,479	318,589	+32,110
S-13	LS Hokota	1,913.60	235,075	244,902	+9,827
S-14	LS Nasu Nakagawa	19,800.00	2,329,367	2,525,170	+195,803
S-15	LS Fujioka A	612.00	78,776	85,084	+6,308
S-16	LS Inashiki Aranuma1	2,725.68	352,232	354,433	+2,201
S-17	LS Fujioka B	2,420.80	312,068	337,458	+25,390
S-18	LS Inashiki Aranuma2	1,200.00	161,321	165,614	+4,293
S-19	LS Sakuragawa Shimoizumi	2,535.04	309,392	339,207	+29,815
S-20	LS Fukushima Yamatsuri	1,327.36	165,610	187,221	+21,611
S-21	LS Shizuoka Omaezaki	1,098.24	138,524	138,916	+392
Total	—	55,834.48	6,698,915	7,137,387	+438,472

End.

TIF Website: <http://tif9281.co.jp/en/>