

October 5, 2018

For Immediate Release

## Infrastructure Fund Issuer

Takara Leben Infrastructure Fund, Inc.

Representative: Masahide Kikuchi, Executive Director

Security Code: 9281

## Management Company

Takara Asset Management Co., Ltd.

Representative: Mamoru Takahashi, President &amp; CEO

Contact: Masahide Kikuchi, Vice President & Director of  
Infrastructure Fund Division,  
Investment Management Department

TEL: +81-3-6262-6402

Notice of Monthly Electricity Generation of Solar Power Generation Facilities for September 2018

Takara Leben Infrastructure Fund, Inc, hereby announces the monthly power generation of the solar power generation facilities under its ownership as of the end of September 2018 as follows.

## 【Monthly Electricity Generation】

Fiscal Period Ending November 2018					
	Number of Solar Power Site	Panel Output (kW)	Forecast Power Generation (kWh) (A) (Note)	Actual Power Generation (kWh) (B)	Difference (kWh) (B)-(A)
June	25	69,551.58	6,779,193	<b>7,935,508</b>	+1,156,315
July	25	69,551.58	7,289,533	<b>9,060,239</b>	+1,770,706
August	25	69,551.58	8,093,560	<b>8,528,178</b>	+434,618
September	25	69,551.58	6,464,706	<b>5,442,964</b>	-1,021,742
October	—	—	5,946,126	—	—
November	—	—	—	—	—
<b>Total</b>	—	—	—	—	—

Due to typhoon, “aki-same” stationary front, and other climate conditions that resulted reduced monthly sunshine duration throughout the nation, electricity generation recorded 5,442,964kWh, which is 15.8% lower than the estimated electricity generation on the basis of the expected amounts of electricity generation in the 50th percentiles of probability of exceedance.

(Note) The estimated electricity generation is the total of the expected amounts of electricity generation in the 50<sup>th</sup> percentile of probability of exceedance calculated by a third party on the basis of the database for hourly solar radiation for a year and others

**【Monthly Electricity Generation by Power Plant】**

September 2018					
No.	Solar Power Site	Panel Output (kW)	Forecast Power Generation (kWh) (A) (note)	Actual Power Generation (kWh) (B)	Difference (kWh) (B)-(A)
S-01	LS Shioya	2,987.25	245,492	<b>214,345</b>	-31,147
S-02	LS Chikusei	1,205.67	104,344	<b>92,820</b>	-11,524
S-03	LS Chiba Wakabaku	705.10	64,020	<b>50,618</b>	-13,402
S-04	LS Miho	1,373.70	124,394	<b>112,370</b>	-12,024
S-05	LS Kirishima Kokubu	2,009.28	201,463	<b>175,938</b>	-25,525
S-06	LS Sosa	1,796.08	174,107	<b>149,928</b>	-24,179
S-07	LS Miyagi Osato	2,040.00	178,249	<b>160,094</b>	-18,155
S-08	LS Mito Takada	2,128.00	192,105	<b>173,657</b>	-18,448
S-09	LS Aomori Hiranai	1,820.00	188,997	<b>208,297</b>	+19,300
S-10	LS Tone Fukawa	2,467.08	270,392	<b>190,674</b>	-79,718
S-11	LS Kamisu Hasaki	1,200.00	119,770	<b>105,538</b>	-14,232
S-12	LS Tsukuba Bouchi	2,469.60	225,200	<b>191,916</b>	-33,284
S-13	LS Hokota	1,913.60	178,029	<b>165,084</b>	-12,945
S-14	LS Nasu Nakagawa	19,800.00	1,709,791	<b>1,438,620</b>	-271,171
S-15	LS Fujioka A	612.00	60,447	<b>50,183</b>	-10,264
S-16	LS Inashiki Aranuma1	2,725.68	270,246	<b>231,307</b>	-38,939
S-17	LS Fujioka B	2,420.80	240,317	<b>200,225</b>	-40,092
S-18	LS Inashiki Aranuma2	1,200.00	121,435	<b>106,368</b>	-15,067
S-19	LS Sakuragawa Shimoizumi	2,535.04	244,982	<b>213,803</b>	-31,179
S-20	LS Fukushima Yamatsuri	1,327.36	124,378	<b>82,115</b>	-42,263
S-21	LS Shizuoka Omaezaki	1,098.24	113,198	<b>88,244</b>	-24,954
S-22	LS Mie Yokkaichi	1,984.50	171,076	<b>140,533</b>	-30,543

S-23	LS Sakuragawa Nakaizumi	2,698.24	257,552	<b>216,219</b>	-41,333
S-24	LS Shirahama	7,839.76	772,196	<b>601,400</b>	-170,796
S-25	LS Takahagi	1,194.60	112,526	<b>82,668</b>	-29,858
<b>Total</b>	—	69,551.58	6,464,706	<b>5,442,964</b>	-1,021,742

End.

TIF Website: <http://tif9281.co.jp/en/>